

Product Specification

Revision: 1
Valid since: 23.01.2001

GLYSACOR® G93® green

PRD number: 30068119
Physical form: Liquid

Test property	Specification	Testmethod
Appearance	green fluorescent	visual
pH value	9.3 - 9.7	ASTM D 1287
Reserve alkalinity of 5 g	11 - 14 ml HCl 0.1 mol/l	ASTM D 1121
Refractive index (20 °C)	1.397 - 1.401	DIN 51 423, part 2
Water content	max. 50.0 %	DIN 51 777, part 1
Density (20 °C) *	1.092 - 1.096 g/cm ³	DIN 51 757, procedure 4

Contains bittering agent.

* (Property not part of the Certificate of Analysis)

The aforementioned data shall constitute the agreed contractual quality of the product at the time of passing of risk. The data are controlled at regular intervals as part of our quality assurance program. Neither these data nor the properties of product specimens shall imply any legally binding guarantee of certain properties or of fitness for a specific purpose. No liability of ours can be derived therefrom.

This is a computer generated document. It is valid without signature.

® = registered Trademark of BASF Group

BASF SE
67056 Ludwigshafen, Germany

Phone: +49 621 60-0
Fax: +49 621 60-42525
E-mail: global.info@basf.com
Internet: www.basf.com

Registered Office: 67056 Ludwigshafen
Registration Court: Amtsgericht Ludwigshafen
Registration No.: HRB 6000

Euro Bank details:
Commerzbank Aktiengesellschaft
Account No. 0201000700, Sort code 545 400 33
IBAN DE26 5454 0033 0201 0007 00
SWIFT COBADEFF545

Deutsche Bank Aktiengesellschaft
Account No. 0013302500, Sort code 545 700 94
IBAN DE72 5457 0094 0013 3025 00
SWIFT DEUTDESM545

Chairman of the Supervisory Board:
Jürgen Hambrecht

Board of Executive Directors:
Martin Brudermueller, Chairman;
Hans-Ulrich Engel, Vice Chairman;
Saori Dubourg, Michael Heinz,
Markus Kamieth, Wayne T. Smith